

# Comparison between treatment of KSWW only and mixture of KSWW and WMWW using subMBR


---

Aileen HUELGAS  
Masashi NAKAJIMA  
Hiroyuki NAGATA  
Prof. Naoyuki FUNAMIZU

Laboratory of Engineering for Sustainable Sanitation  
Graduate School of Engineering, Hokkaido University, JAPAN

# Background of Study

## Onsite Wastewater Differentiable Treatment System



## Submerged Membrane Bioreactor (SubMBR)

### Advantages:

- longer sludge retention time (SRT) independent of hydraulic retention time
- smaller footprint
- small reactor volume due to higher MLSS concentration and loading rate
- complete removal of solids
- higher and more consistent effluent quality suitable for reuse
- reduced sludge production.

### Objectives

- To determine effect of organic loading rate (OLR)
  - organic matter removal
  - nitrogen and phosphorus
  - LAS removal\*

\* Mixture only

## Ultrafilter-Hollowfiber (UF-HF)

---


### **Kitchen Sink (KS)**

1. Effect of organic loading rate (OLR) on:  
organic matter(OM) removal;  
characteristics of OM; nitrogen  
and phosphorus (N and P)

### **Kitchen Sink and Washing Machine (KS + WM)**

2. Effect of OLR on:  
OM removal; N and P; permeate  
flux; LAS


# Configurations of a single subMBR



## Operating conditions at different HRT to give different OLR

Parameters	Reactor 1	Reactor 2	Reactor 3	Reactor 4
TMP, kPa	5	5	5	5
HRT, hr	<b>4.5</b>	<b>7</b>	<b>12</b>	<b>24</b>
MLSS, g/L	11-13	11-13	11-13	11-13
Airflow Rate, L/min	2.5	2.5	2.5	2.5

### Parameters monitored



## Kitchen sink wastewater characteristics

Parameters (mgL <sup>-1</sup> )	Kitchen sink	Gr	Mixture	nestic <sup>2</sup>
<b>COD</b>	770-2050	495	540-1200	0-800
<b>Total Nitrogen (TN)</b>	21.9-43.5	8.0-	10-35	0-70
<b>Particulate Organic N</b>	12.7-24.4			
<b>Dissolved Organic N</b>	6.1-14.2		9-32	
<b>NH<sub>4</sub>-N</b>	0.3-2.7		0.9-2.6	
<b>NO<sub>3</sub>-N</b>	0.9-5.3		0.2	
<b>Total Phosphorus(TP)</b>	2.9-14.5	4.6	0.6-1.3	-12
<b>Phosphates (PO<sub>4</sub>-P)</b>	0.4-1.5			

<sup>1</sup>Palmquist & Hanæus 2005

<sup>2</sup>Tchobanoglous *et al* 2003

## Operating conditions and permeate quality of the reactors of different organic loading rate

	Reactor 1	Reactor 2	Reactor 3	Reactor 4
<b>HRT</b> , hr	4	8	12	24
<b>OLR</b> , kg COD/m <sup>3</sup> -day	5.3	2.7	1.8	0.9
<b>MLSS</b> , g/L	9-11	9-11	9-11	6-7
<b>SRT</b> , days	-	30	58	Almost infinite
<b>F/M</b> , kgCOD/kgMLSS-day	<b>0.53</b>	<b>0.27</b>	<b>0.18</b>	<b>0.14</b>
<b>F/M for KS only</b>	<b>0.575</b>	<b>0.375</b>	<b>0.217</b>	<b>0.165</b>
<b>Permeate</b>				
<b>COD</b> , mg/L	<b>53</b>	<b>29</b>	<b>17</b>	<b>17</b>
		(82.5)	(59.4)	(29.3)
<b>NH<sub>4</sub>-N</b> , mg/L	-	0.1*	0.55*	0.06*
<b>NO<sub>3</sub>-N</b> , mg/L	-	0-0.01	0-0.41	0-3.67
<b>PO<sub>4</sub>-P</b> , mg/L	-	-	-	0-0.54

\*ave value

## Dissolved matter inside each reactor of different OLR

	Reactor 1	Reactor 2	Reactor 3	Reactor 4
<b>COD</b> , mg/L	-	97-272	64-240	58-235
<b>NH<sub>4</sub>-N</b> , mg/L	-	0.21*	0.63*	0.07*
<b>NO<sub>3</sub>-N</b> , mg/L	-	0-0.2	0-0.47	0-3.72
<b>PO<sub>4</sub>-P</b> , mg/L	-	-	-	0-0.65

\*ave value

### Measurement of LAS

- LAS concentration in washing machine wastewater:  
→ 20.59 - 46.24mg/L
- LAS concentration in permeate  
→ 0.008 – 2.400 mg/L

## Summary

- Biological treatment of WMWW only is not feasible
- HRT = 8 hours or longer / OLR = 2.7 kgCOD/m<sup>3</sup>-day or lower
- High organic matter in the permeate of the system treating the mixture compared to KSWW only
- WMWW has some components that are not completely degraded
- Remaining OM is not LAS

*THANK YOU...*

## Operating conditions and permeate quality of the reactors of different organic loading rate

	Reactor 1	Reactor 2	Reactor 3	Reactor 4
<b>HRT</b> , hr	4.5	7	12	24
<b>OLR</b> , kg COD/m <sup>3</sup> -day	6.9	4.5	2.6	1.3
<b>MLSS</b> , g/L	11-13	11-13	11-13	7-9
<b>SRT</b> , days	15	25	140	Almost infinite
<b>F/M</b> , kgCOD/kgMLSS-day	0.575	0.375	0.217	0.1625
<b>Permeate</b>				
<b>COD</b> , mg/L	35-73 (53)	11-53 (29)	10-26 (17)	7-34 (17)
<b>NH<sub>4</sub>-N</b> , mg/L	-	-	-	-
<b>NO<sub>3</sub>-N</b> , mg/L	-	-	-	13
<b>PO<sub>4</sub>-P</b> , mg/L	-	0.05	0.8	2.4

## Dissolved matter inside each reactor of different OLR

	Reactor 1	Reactor 2	Reactor 3	Reactor 4
<b>COD</b> , mg/L	44-1213	34-207	19-131	23-54
<b>NH<sub>4</sub>-N</b> , mg/L	-	-	-	-
<b>NO<sub>3</sub>-N</b> , mg/L	-	-	-	13
<b>PO<sub>4</sub>-P</b> , mg/L	-	0.1	0.9	2.3