

TUBITAK MARMARA RESEARCH CENTER Environment Institute

APPRAISAL OF TECHNICAL OPTIONS for GREY WATER TREATMENT PROCESSES

A. Baban, S. Murat Hocaoglu, E. Atasoy, M. Regelsberger



WASTEWATER IN SMALL COMMUNITIES
TOWARDS THE WATER FRAMEWORK DIRECTIVE (WFD)
AND THE MILLENNIUM DEVELOPMENT GOALS (MDG)


INTRODUCTION

- GW from laundry, dishwashing, bathing
- Low OM, nutrients, pathogens
- Reuse to mitigate water stress, due to climate change
- Achieve SWM in Mediterranean region
- Reused for non-drinkable purposes

Objectives

- Provide information on appraisal of GW treatment options for
effluent quality, efficiency, reliability,
operation, economy,
compliance reuse standards





GW inlet characteristics

- 2 buildings (28 apartmens)
- 18-26 people (21 avg)
- 18 month period results
- Flow
Q= 197 l/c-d (60%BW 40% GW)




parameter	Influent avg. (std. dev.)
pH	7.2 (0.3)
COD _T , mgL ⁻¹	295 (79)
COD _{sol} , mgL ⁻¹	191(54)
BOD ₅ , mgL ⁻¹	110 (55)
T Coliform /100mL,	>10 ⁶
Turbidity, NTU	90 (50)
TSS, mgL ⁻¹	63 (30)
TKN, mgL ⁻¹	7.4 (3.7)
NH ₄ ⁺ -N, mgL ⁻¹	1.6 (1.4)
TP, mgL ⁻¹	7.3 (3.1)
Alkalinity, CaCO ₃ , mgL ⁻¹	192 (29)

Treatment Unit	Operational parameters
<p>RBC</p>	<p>Q= 150 and 400 l/d D=46cm discs (36) radial and concentric passages A=16 m² R=2-3 rpm OL R= 3.5 and 8.6 gCOD m²/d HLR = 0.03 m³/m²d connected settling chamber</p>



Treatment Unit	Operational parameters
CW systems	<p>Q= 1000 l/d</p> <p>area</p> <p>HF – CW = 28 m²</p> <p>FWS – CW = 35 m²</p> <p>HLR for HF = 36 l/m².d</p> <p>Feeding by submerged pump</p>



Treatment Unit	Operational parameters
<p>MBR</p>	<p>Q= 800 l/d V= 600 L working vol. BUSSE GmbH Company a micro-filtration plate and frame module (KUBOTA) T. filtration area = 5 m² HRT=18h OL=0.3 kgCOD/m³-d Feeding by submerged pump</p>




Treatment Unit	Operational parameters
<p style="text-align: center;">SBR</p>	<p>Q= 400 l/d V= 600 L total working vol. by PONTOS GmbH., 2 serial chambers for biological reactions (400L) 3rd tank for storage including UV disinfection. Hybrid SBR had suspended and attached biomass HRT=0.5+0.5 d OLR = 0.15 kg BOD₅/m³ Feeding by submerged pump</p>




	pH	BOD mg ^l ⁻¹	TSS mg ^l ⁻¹	Fecal C. Number/ 100 ml	E.Coli Number/ 100ml
EPA Suggested Guidelines for water reuse, 2004 [8]					
<i>Urban reuse;</i> All types of landscape irrigation, vehicle washing, toilet flushing, and other uses with similar access or exposure to the water					
	6-9	≤ 10	≤ 5	ND	-
<i>Agricultural reuse; Food crops not commercially processed</i>					
	6-9	≤ 10	≤ 5	ND	-
<i>Agricultural reuse; Food crops commercially processed</i>					
	6-9	≤ 30	≤ 30	<200	-
EU Guidelines (76/160/EEC)[9]					
Bathing waters					
	6-9	-	-	100 (G); 2,000 (M)	-
WHO (guideline value for grey water use in)[10]					
Restricted irrigation					
	-	-	-	-	<10 ⁵
Unrestricted irrigation of crops eaten raw					
	-	-	-	-	<10 ³
Lawn irrigation					
	-	-	-	200 (G), 1000 (M)	-
Turkey, Water Pollution Control Regulation (WPCR), [12]*					
Irrigation					
	6.5-8.5	≤100	≤45	≤100	-

(G) guideline, (M) mandatory

Treated GW characteristics





Comparison of GW treatment systems





Parameters

Comparison of GW treatment systems



Comparison of GW treatment systems



Assessment of GW treatment technologies applied in this study

Parameters / GW technology	MBR	SBR	RBC	CWs
Operator technical level	high	high	low	low
Sludge , L/ m ³ GW-d	5	4-5	1-3	-
Disinfection requirement	no	no (inc. UV)	yes	no
Effluent for reuse,	unrestricted reuse	irrigation, with filtration	irrigation with filtration+UV	irrigation

Results

- All cases high removal efficiencies
- Best removal performance was obtained with the MBR
- Effluent quality satisfied EPA suggested guidelines urban reuse criteria including toilet flushing
- For all alternatives at least criteria for agricultural reuse for food crops commercially processed (EPA Guidelines) fulfilled mostly.
- Criteria violated sometimes for TSS and turbidity due to detached particles RBC and some deteriorations in effluent for SBR → filtration (gravity or pressure recommended)
- For RBC UV disinfection advisable
- For net revenue, calculated based on local electricity and water prices, (5% levelling factor and 5% interest)
- CWs systems are proved to be favorable.

Conclusions

- It was experienced that the most qualified staff required technology for operation is MBR.
- RBC and CWs are quite advantageous for the point of operational ease
- Each system designed and operated possesses own advantages,
- Local conditions in terms of economic, social, environmental and hygienic concerns play the virtual role for appraisal

THANKS

